



# Certificate of Compliance

**Certificate:** 70024231

**Master Contract:** 206947

**Project:** 80014595

**Date Issued:** October 07, 2019

**Issued to:** PR Electronics A/S  
Lerbakken 10  
Ronde,  
DK-8410  
DENMARK

**Attention:** Peter Bergmann

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and US Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only*



**Issued by:**

Oong Lee

## PRODUCTS

**CLASS 2258 04** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations

**CLASS 2258 84** - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations - Certified to US Standards

**Class I, Division 1, Groups A, B, C, and D T6...T4; Class II, Division 1, Groups E, F, and G; Class III Ex ia IIC T6...T4 Ga**

**Class I, Zone 0, AEx ia IIC T6...T4 Ga**

Model 7501A.....2 and 7501B.....2 Temperature transmitters

Supply Terminal: 1,2 - Ui: 30 VDC; Ii: 120 mA; Pi: 0.84 W; Li: 0  $\mu$ H; Ci: 2 nF

Sensor Terminal: 3,4,5,6 - Uo: 9.6 VDC; Io: 28 mA; Po: 67 mW; Lo: 35 mH; Co: 3.5 $\mu$ F

Enclosure rated: IP68, Type 4X

Refer to installation drawing #7501QC01



Certificate: 70024231

Master Contract: 206947

Project: 80014595

Date Issued: October 07, 2019

* Temperature Ratings	
IS / Ex ia	
T4	$-20/-40^{\circ}\text{C} \leq T_a \leq 85^{\circ}\text{C}$
T5	$-20/-40^{\circ}\text{C} \leq T_a \leq 60^{\circ}\text{C}$
T6	$-20/-40^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$

**CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations**

**CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations**

**Class I, Division 1, Groups A, B, C and D T6...T4; Class II, Division 1, Groups E, F and G; Class III:  
Ex d IIC T6...T4 Gb**

**Class I, Zone 1, AEx d IIC T6...T4 Gb**

7501A.....2 Series Temperature transmitters rated 10 – 35 VDC, 23mA. Enclosure rated: IP68, Type 4X. Refer to installation drawing #7501QC01

**Conditions of Acceptability:**

1. Only third party certified sensors suitable for Class I, Division 1 Groups ABCDEFG or Zone 1, IIC may be attached to the 7501 Temperature Transmitter without additional approval of the combination.
2. Only Blind Plugs type 8550-xxx and 8551-xxx supplied with the 7501 or third party certified Blind Plugs suitable for the application and correctly installed may be used

Temperature Ratings	
XP / Ex d / DIP	
T4	$-20^{\circ}\text{C}/-40^{\circ}\text{C} \leq T_a \leq 85^{\circ}\text{C}^{**}$
T5	$-20^{\circ}\text{C}/-40^{\circ}\text{C} \leq T_a \leq 85^{\circ}\text{C}^{**}$
T6	$-20^{\circ}\text{C}/-40^{\circ}\text{C} \leq T_a \leq 70^{\circ}\text{C}^{**}$



**Certificate:** 70024231

**Master Contract:** 206947

**Project:** 80014595

**Date Issued:** October 07, 2019

### APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-10 CSA Std C22.2 No. 142- M1987(R2009) CSA Std C22.2 No. 157-92 (R2012)	General Requirements-Canadian Electrical Code, Part II Process Control Equipment  Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations
CAN/CSA C22.2 No. 60079-0:11 CAN/CSA C22.2 No. 60079-11:11	Explosive atmospheres — Part 0: Equipment — General requirement Electrical Apparatus for Explosive Gas Atmospheres – Part 11: Intrinsic Safety "i"
UL Std No. 913, Ed. 8	Intrinsically Safe Apparatus and for use in Class Associated Apparatus I, II, and III, Division 1, Hazardous (Classified) Locations
UL Std No. 916, Ed. 4 UL 60079-0, Ed 5 UL Std No. 60079-11, Ed. 6	Energy Management Equipment Explosive atmospheres — Part 0: Equipment — General requirement Electrical Apparatus for Explosive Gas Atmospheres - Part 11: Intrinsic Safety "i"
CAN/CSA C22.2 No. 25-1966 CAN/CSA C22.2 No. 30-M1986 CAN/CSA C22.2 No. 94-M91 CAN/CSA 60079-1:11	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations Explosion-Proof Enclosures for Use in Class I Hazardous Locations Special Purpose Enclosures Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d" - Second Edition
C22.2 No. 60529:05 FM 3600	Degree of Protection Provided by Enclosures (IP Code) Electrical Equipment for Use in Hazardous (Classified) Locations General Requirements.
FM 3615	Explosionproof Electrical Equipment for Hazardous (Classified) Locations
FM 3810	Electrical And Electronic Test Measuring, and Process Control Equipment
ANSI/ISA-12.00.01	Electrical Apparatus for Use in Class I, Zone 1 Hazardous (Classified) Locations Type of Protection - Flameproof "d"
ANSI/IEC 60529	Degrees of Protection Provided by Enclosures (IP Code)



**Certificate:** 70024231

**Master Contract:** 206947

**Project:** 80014595

**Date Issued:** October 07, 2019

## **MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Markings information as shown below and appear on a metal nameplate or adhesive aluminum foil which is secured to enclosure by screws. Separate labels markings are required for Division and Zone.

- Manufacturer's name: "PR Electronics", or CSA Master Contract Number "206947", adjacent to the CSA Mark in lieu of manufacturer's name.
  - Model number: As specified in the PRODUCTS section, above.
  - Electrical ratings: As specified in the PRODUCTS section, above.
  - Ambient temperature rating: As specified in the PRODUCTS section, above.
  - Manufacturing date in MMY format, or serial number, traceable to year and month of manufacture.
  - Enclosure ratings: As specified in the PRODUCTS section, above.
  - The CSA Mark, as shown on the Certificate of Conformity.
  - Hazardous Location designation: As specified in the PRODUCTS section, above (may be abbreviated).
- Temperature code: As specified in the PRODUCTS section, above.

For Class 2258 04/ 2258 84 Model 7501A.....2 and 7501B.....2 Temperature transmitters

- The following warnings and cautions:
  - "Install per drawing number 7501QC01"
  - "INTRINSICALLY SAFE" and "SÉCURITÉ INTRINSÉQUE"
  - "Exia"

For Class 2258 02/ 2258 82 Model 7501A.....2 Series Temperature transmitters

- The following warnings and cautions:
  - "OPEN CIRCUIT BEFORE REMOVING COVER" and "OUVRIR LE CIRCUIT AVANT D'ENLEVER LE COUVERCLE", or "KEEP COVER TIGHT WHILE CIRCUITS ARE ALIVE" and "GARDER LE COUVERCLE BIEN FERME TANT QUE LES CIRCUITS SONT SOUS TENSION" or the equivalent.